

**Network Operations Center
Weekly OUTAGE Report
06/01/2009 - 06/07/2009**

| Incident Number | Type | Title | Date Submitted | Date Resolved | Incident Solution |
|------------------------|-----------------------------|--|-----------------------|----------------------|--|
| 70061 | PSA Network Connectivity | Connectivity: AE_Bamberg_2801, 06/03/09 8:38AM | 06/03/09 | | Circuit has been bouncing since 05/23/09. AT&T have replaced several cable pair, but this issue is not resolved. |
| 69839 | Campus Network Connectivity | Outage: Poole-UpStr-Main_3750, 06/02/09 7:12AM | 06/02/09 | 06/02/09 | Network equipment in Poole required manual reboot after power outage. Service restored at 10:40AM. |
| 69820 | Campus Network Connectivity | Power Outage: Cooper, Earle, Freeman, Poole, Hydraulics Lab, Lowry, Landscape Services, Athletic Shed and Indoor Track 06/02/09 7:28AM | 06/02/09 | 06/02/09 | Loss of connectivity due to power outage. Service restored to all locations except Poole by 8:40AM. |
| 69779 | Campus Network Connectivity | Outage: Fike-BE_3560G24P-11, 06/01/09 5:18PM | 06/01/09 | 06/02/09 | Loss of connectivity due to broken fiber jumper. Jumper replaced and service restored 06/02/09 at 5:44PM. |